

## HURRICANE PROCEDURES FOR WATER WELL WATER SYSTEMS

Support 407-323-9010

**CAUTION: CONSULT A QUALIFIED ELECTRICIAN IF THERE IS ANY DOUBT REGARDING THE SAFETY OR RELIABILITY OF ANY ELECTRICAL DEVICE.**

### IF YOU EVACUATE

- Turn the softener and filter valves to bypass.
- Turn off the water at the main inlet valve.
- Turn off the electricity at the main circuit breaker.
- Secure all loose lids, covers, etc.

WHEN YOU RETURN, BE SURE IT IS SAFE, THEN FOLLOW THE

### RESTART PROCEDURE

- Inspect for damage. Repair as needed.
- Turn on the electricity.
- Turn on the water at the main inlet valve.
- Set the clocks on the softener and filter.
- Make sure there is adequate chlorine.
- Open the filter and softener bypass valves.
- Flush water through system for 20 minutes before use. Slowly!

### IF YOU DON'T EVACUATE

- Store water in jugs and other containers. If you lose electric power, you will have water.

### IF IT IS LIKELY THAT THE ELECTRIC UTILITY WILL LOSE POWER:

- Turn the softener and filter valves to bypass.
- Turn off the water at the main inlet valve.
- Turn off the electricity at the main circuit breaker.
- Secure all loose lids, covers, etc.

WHEN ELECTRICITY IS RESTORED FOLLOW THE RESTART PROCEDURE ABOVE.

## REVERSE OSMOSIS, WHOLE HOUSE

### IF YOU EVACUATE

- Fill the storage tanks with product water. Add one teaspoon of bleach per 100 gallons to guard against microbiological contamination.
- Close valves and turn off pumps to conserve water.
- Turn off the electricity at the main circuit breaker.

WHEN YOU RETURN, BE SURE IT IS SAFE TO:

- Inspect for damage and possibility of contamination.
- Turn on electricity.

- Check all systems for normal operation.
- Restart system.

IF YOUR WATER SYSTEM SUSTAINED DAMAGE IT MAY BE CONTAMINATED. REPLACE THE MEMBRANE, PRE-FILTERS AND POST FILTERS.

### SERVICE PROCEDURE

- Remove the membrane if it may be contaminated.
- Do not allow bleach or chlorine to contact the membrane.
- Remove the pre-filter and post-filter cartridges
- Wash filter housings in bleach solution. Rinse with clean water.
- If the pump and system are contaminated, pump a 1% solution of chlorine into the system, let stand 20 minutes then run until chlorine is removed.
- Install new membrane and cartridges.
- Re-start the system.

Copyright © 2004 Discount Water Supply, Inc. All Rights Reserved.